



## 2012 Statement of Opportunities Pre-launch briefing


Greg Ruthven  
Manager, System Capacity

18/6/2012

# Agenda

- 2011/12 summer
- SWIS electricity demand forecasts – 2012/13 to 2022/23
- Emerging trends
- 2014/15 Reserve Capacity Requirement


# 2011/12 summer



## 2011/12 peak demand

- Peak demand 3,854 MW
  - 25 Jan, 16:30-17:00
- 0.6% above 2010/11 peak
- Substantially lower than forecasts
  - 327 MW below 50% PoE forecast
  - Timing of peak (100-200 MW)
  - Solar PV (approx 50 MW)
  - New major loads (117 MW)


# 2011/12 sent out energy



## 2011/12 sent out energy

- Projected sent out energy 17,673 GWh
- Expected forecast 19,088 GWh
- Solar PV (~ 200 GWh)
- New major loads (~ 700 GWh)

# Temperature-corrected energy sales



## Demand forecasts

- IMO contracts NIEIR to produce SWIS demand forecasts
- Demand for generation and DSM capacity – not end customer consumption
  - Accounts for transmission losses
  - Ensures consistent basis with capacity certification
- Ten year forecast horizon
  - Peak demand and annual energy: Expected, High and Low economic growth scenarios
  - Peak demand: 10%, 50%, 90% PoE




## How are forecasts produced?

- Top-down econometric models link electricity consumption to a range of factors such as:
  - economic activity by industry sector
  - population, household size and customer numbers
  - appliance penetration and efficiency
  - household incomes
  - energy prices
  - weather conditions
  - major new loads
- Bottom-up end use models


## Dealing with change

- Prepared using best available information at the time
- Reviewed annually to reflect:
  - changes to input variables
  - changes to relationships between input variables and electricity consumption

# Forecast history



# Forecast history




## Temperature sensitive load growth

- NIEIR's forecasts consider temperature sensitive and non-temperature sensitive load
- Consider air conditioner sales and characteristic of available systems
- Strong growth in temperature sensitive load in first decade of 2000's
- Trend has changed – recalibration of model in 2011, approx 300 MW reduction

## New major loads

- New loads can lead to substantial increase in demand
- Separately considered in demand forecasts
- Uncertainty around development decisions, project timing



## Small-scale solar PV

- Penetration has increased sharply in a few years:
  - Government subsidies, including feed-in tariffs
  - Decreasing system costs
- Seen by market as reduced consumption
- Not previously considered due to lack of information
- Reduction in peak demand forecasts approaches 200 MW by 2023


# Peak demand forecasts



Growth rate 3.0% pa



# Energy forecasts



Growth rate 2.1% pa

# Influences on future electricity consumption

- Potential of solar PV in commercial & industrial sectors
- Energy efficiency programs
- Initiatives enabled by smart meters

Measure	Reported impact
In-Home Displays	6.8% reduction in energy consumption
Living Smart behaviour change program	8.5% reduction in energy consumption
Direct Load Control of air-conditioners	20% reduction at peak time
Time of use tariffs	10.9% reduction at peak time
Home Eco-Consultations	7.8% reduction in energy consumption

Perth Solar City, Annual Report 2011

## Reserve Capacity Target

- Critical parameter for Reserve Capacity Mechanism
- Require sufficient capacity in two years' time to:
  - meet 1-in-10 year (10% PoE) peak demand
    - + reserve margin (8.2% of peak or largest generator)
    - + allowances for frequency keeping and embedded generation
  - limit expected unserved energy to 0.002% of annual consumption
- **Reserve Capacity Target for 2014/15 is 5,308 MW**

## Reserve Capacity Target – 2013/14 to 2014/15


<b>2013/14 Reserve Capacity Requirement</b>	<b>5,312 MW</b>
Changes to 2013/14 block load assumptions (plus 8.2%)	+ 9 MW
Additional block load assumed for 2014/15 (plus 8.2%)	+ 16 MW
Inclusion of 2013/14 solar PV (plus 8.2%)	- 77 MW
Additional solar PV for 2014/15 (plus 8.2%)	- 14 MW
Change to Load Following requirement	- 5 MW
Year-on-year change in underlying demand forecast	+ 67 MW
<b>2014/15 Reserve Capacity Requirement</b>	<b>5,308 MW</b>

## Availability Curve

- Seeks to ensure capacity with sufficient availability to satisfy year-round energy requirements

Availability Curve Information	2013/14 (MW)	2014/15 (MW)	2015/16 (MW)
<b>Market Rule 4.5.12(a):</b>			
Capacity required for more than 24 Hours	4,469	4,605	4,741
Capacity required for more than 48 Hours	4,300	4,429	4,561
Capacity required for more than 72 Hours	4,188	4,314	4,441
<b>Market Rule 4.5.12(b):</b>			
Minimum Generation Required	4,281	4,438	4,592
<b>Market Rule 4.5.12(c):</b>			
Capacity associated with Availability Class 1	4,281	4,438	4,592
Capacity associated with Availability Class 2	19	0	0
Capacity associated with Availability Class 3	169	167	150
Capacity associated with Availability Class 4	677	703	731

# Supply-demand balance



# Questions